

Performance Evaluation of Deregulated Power System Static Security Assessment using RBF-NN Technique

I. S. Saeh^{a*}, M. W. Mustafa^a


^aFaculty of Electrical Engineering, Universiti Teknologi Malaysia, 81310 UTM Johor Bahru, Johor, Malaysia

*Corresponding author: saiiabrahem2@live.utm.my

Article history

Received :8 July 2013
Received in revised form :
10 August 2013
Accepted : 15 August 2013

Graphical abstract



Abstract

This paper proposes RBF-NN for classification and performance evaluation of static security assessment in deregulated power system. This study suggests an attribute selection and classification algorithms for static security evaluation (SSE) and its impact is proposed. For the base case, pure pool dispatch (with no bilateral transactions) and bilateral transaction comparisons are discussed on IEEE57- bus system. In this paper, a comprehensive comparison of AI classifiers to examine whether the power system is secured under steady-state operating conditions is presented. The proposed classifier is implemented on a 30 and 57 IEEE test system. To assess the actual overall performance regarding studying techniques, this research proposes performance evaluation schemes vis CCR, TPR and TNR and implemented on various IEEE test systems. The simulation results have shown the powerfulness of the proposed method as compare to another proposed AI classifiers.

Keywords: Intelligence techniques; performance evaluation; static security; pool and bilateral transactions

Abstrak

Kertas ini mencadangkan RBF-NN untuk klasifikasi dan penilai prestasi keselamatan statik dalam sistem kuasa yang dikawal selia. Kajian ini mencadangkan pemilihan sifat dan algoritma klasifikasi bagi penilaian keselamatan statik (SSE) dan kesannya dibincangkan. Bagi kes asas, penghantaran kolam tulen (dengan tiada transaksi dua hala) dan perbandingan transaksi dua hala akan dibincangkan pada sistem IEEE57-bus. Dalam kertas ini, perbandingan komprehensif pengelasan AI untuk memeriksa sama ada sistem kuasa adalah terjamin di bawah keadaan operasi mantap dibentangkan. Pengelasan yang dicadangkan dilaksanakan pada sistem ujian IEEE 30 dan 57. Untuk menilai prestasi keseluruhan sebenar teknik-teknik yang dipelajari, kajian ini mencadangkan skim penilaian prestasi melalui CCR, TPR dan TNR dan dilaksanakan pada pelbagai sistem ujian IEEE. Keputusan simulasi telah menunjukkan ketahanan kaedah yang dicadangkan berbanding dengan yang lain yang dicadangkan pengelasan AI.

Kata kunci: Teknik pintar; penilaian prestasi; keselamatan static; transaksi kolam dan dua hala

© 2013 Penerbit UTM Press. All rights reserved.

1.0 INTRODUCTION

Around the world, the electric power section has been moved to operate from the traditional way, “vertically integrated system” to the deregulation system environment. In this, independent entities are owned and operated the three main wings of the system; the generation, transmission and distribution. A deregulated power system established a new market structure to assist the possibility of selling and buying electricity as a commodity.

For operations and efficiency improvements, the sector of electric power has been shifted from vertically to deregulation. This has brought along a number of issues concerning the security, especially, of large systems [1]. In the contingency's occurrence, dramatic disturbances may cause to supply the electric power and

significant damages from the economic perspective as well. And as a result, the research efforts are motivated to classify the power systems, whether secure or not.

Electric utilities are organizations that produce, deliver, distribute or sell electric power [2]. The electric power system in general is composed of generation, transmission and distribution facilities. Different countries have different power industry structures and may be either regulated or deregulated because of the economic and social differences between the countries, but the industry frameworks, however, are all generally have some similar characteristics [3]. In this type of industry structure, the required revenues are directly related to the cost-of-service based on investment. One of the advantages of the traditionally regulated

industry is in the coordination of all the functions required to provide a highly reliable electricity supply.

Traditional regulated industry structures have existed for a long time [2, 3]. In recent years, the regulated power industry has to adapt to social, economic, political and technical changes. Competition has become the key factor driving the deregulation process in the electric power industry, and should benefit both the customers and the participating companies. The key concept behind deregulation in almost every country is that no one company should have a monopoly on other segments of the system.

The operator looks at if the system security restrictions tend to be fulfilled as well as, if required, readjusts the actual pool as well as bilateral stages [4]. An alternative to the strategy would be to send out a level of sensitivity indicators towards the two-sided partners who help these re-negotiate the actual two-sided agreements based upon the stage and placement regarding blockage. A good electrical power industry design along with a combined pool/bilateral procedure was analyzed within [5].

A typical trend rising in the market-oriented framework is the fact that numerous dealings are going to be produced. Obviously, the fundamental device could be decreased to some two-sided deal. Actually, every multilateral deal may also be symbolized by a pool of synchronized two-sided dealings. The existence of these kinds of two-sided dealings, consequently, determines the actual 'state' of the power system simply because almost all marketing organizations (generation) and purchasing organizations (loads) should behave in order to satisfy their particular agreement responsibility [6]. In the deregulated environment [7], the amount of two-sided dealings will certainly develop quickly and for that reason, brand new techniques as well as resource is going to be needed to assist program providers assess their particular influences around the procedure in the methods.

In the current power system process, the more the particular monitoring period, the more effective the contingency analysis. AI's tend to be well-suited to cope with design identification within an impressive approach, as they possibly can learn off line as well as utilized on-line in order to categorize black outs many thanks credited their own generalization abilities. The use of AI sets of rules regarding SSE with power system security continues to be recommended as well as proposed by a lot of scientists. A great security checking plan should be in a position to evaluate each overloading as well as current modifications. A good since outcome, SA has proven one of the most versatile AI technique's applications leading to a large number of publications and an advanced application stage.

A particular advantage to this technique is the possibility to define new measures of system adequacy in terms of the overloading of components and/or violations of bus voltage limits. Significant progress has been made to reduce the complications of these techniques [8, 9].

To treat extremely complicated methods, a lot of improvements have been created with Monte Carlo simulation methods [10]. These techniques are extremely versatile within their management of program problems as well as working methods. Their own primary drawback is actually extreme calculation occasions in order to take into account situations regarding little possibility. To beat the unnecessary calculation periods, efforts have already been designed to be able to help determine the actual adequacy of the power system with a few estimates but still give an acceptable indicator regarding adequacy actions in the program [11]. Several estimated methods happen to be accustomed to determine the actual adequacy indices of huge power methods [12, 13]. These types of approximation techniques make use of simple logic or even estimated remedy methods. They almost don't, nevertheless, think about most reputable blackouts as well as problems that may significantly modify the actions on the power

system. In recent years, many Artificial Intelligence (AI) techniques have been proposed to overcome the pitfalls of the traditional method of security evaluation. The important issue when confronted with AI classifiers is just not regardless of whether the understanding formula surpasses many others, however, to which circumstances a specific technique can easily considerably outshine some others on the provided software difficulty. By these types of circumstances, any kind of disruption might jeopardize the machine protection and also the dependence on online reliability evaluation as well as manage to real-time nature has become greater and better. Consequently, there exists a demanding must create quick on-line security checking technique, that could evaluate the amount of security as well as forewarn program providers to consider required precautionary measures just in case require occurs [14]. This process is extremely time intensive as well as infeasible regarding real-time programs [15, 16]. This specific necessitates the requirement for creating a far more effective method to obtain program security position applying real-time data.

ANN has been proposed for many areas in electric power, such as monitoring and control is [17], static security assessment, line-flow contingency screening and fast voltage [18], two-class PR difficulty [19], [20]. Neural network and wavelet transform has been suggested for assessing online voltage stability [21]. SVM is introduced to information system security (ISS), assurance capability assessment (ACA), constructs a corresponding assess model in [22]. Based on SVM, [23] proposes a network safety risk assessment method. SVM is applied to judge the transient stability of power system networks after faults happened on transmission lines [24].

ANN [25-28] provides efficient in addition to fast evaluation for a large power system in comparison with the conventional method, for example, load flow together with load flow methods. These techniques happen to be utilized cautiously in the area relating to power system. The most common strategy is ANN, due to the ability to classify styles along with its exceptional dependability in comparison with various device understanding strategies. The disadvantages might be discussed in [29]. You will discover several types of ANN where every type works in a specific program. A lot of the created as well as released initiatives in this particular area utilize the multilayer perception (MLP) style based on a back propagation (BP) formula, which usually is affected with historical minima in addition to over fitting problems.

■2.0 DATA GENERATION

Prior to AI execution, NRLF evaluation is utilized to fix synchronized nonlinear algebraic formula regarding check program as well as collected just about all bus voltages as well as line flow data. Much data is utilized to enter because the AI regarding coaching as well as evaluating. This makes use of the actual Taylor's sequence expansion along with a consecutive approximation according to preliminary approximate to the unfamiliar guidelines. The actual NRLF evaluation produced by matpower 3.0b4 software program [30] and it is utilized through the research. This program demands current bus data as well as collection power flow data from the program inside a matrix style. The outcomes can be shown utilizing order runpf ('case X'), exactly where X is actual quantity of buses.

All of the data from Newton Raphson technique is going to be utilized because the coaching (75%) as well as screening (25%) data for those AI methods. Consequently, the exam arranged (data); that is various instances in the coach data ought to keep up with the proportionality to get the outcomes of appropriate precision.

Within the simulation stage, the actual planned intelligent supervised artificial intelligence methods had been applied via 3

ways: data selections as well as pre-processing, instruction stage, as well as simulation execution.

Each style is really seen as several sets attribute, creating the parts concerning style vector $X_{SSE} = (X_1, X_2, X_3, X_n)$. By means of digesting the security index, each and every style is really labelled or perhaps regarded as belonging to one of the 2 groups - Secure (Binary one) as well as Insecure (Binary zero) as appears in table 1.

Table 1 Class label for security evaluation

| Class Category / Label | SSE |
|------------------------|-----|
| Class A : Secure | (0) |
| Class B : Insecure | (1) |

3.0 DATA NORMALIZATION

Normalization is a preliminary step that needs to be processed for each data set. The normalization technique is to transform the data into a manageable scale for easiness of network training and guarantee of convergence. The RBF Network obtains a forecasted value in a provided enter continues through creating the actual measured summary of facilities, which are (blank) towards the provided enter. Therefore, the actual efficiency to the system is conditional severely around the measurement accustomed to determine the actual nearness. Nevertheless, this method has its own effect; when we convey more than a single enter variable, which enter factors tend to be considerably distinct when it comes to weighing scales, then your nearness is dependent nearly positioned on the real variable with all the biggest scaling. To avoid this issue, it's important to be able to standardize the size of the enter variables. Any time almost all enter variables had exactly the same sequence associated to a degree; the actual formula works much better.

These types of factors are known as 'input attributes' developing the parts of the feature vector Z_{SSE} . The actual feature selection is actually; therefore, a procedure regarding dimensionality reduction, in which an ideal part regarding characteristics that tend to be chosen from the big dimension design vector. Usually the characteristics which may be applied to explain a power system condition tend to be:

- (1) The voltage magnitude of each bus.
- (2) The active and reactive power flow of all the lines.

For static security evaluation, voltage magnitude (U_k) of each bus and the thermal power (S) of all the lines must be in their limitations. Those limitations are:

$1.06 > U_k > 0.94$ and $S < S_{max}$, and the attribute vector Z will consists of these variables.

4.0 ATTRIBUTE SELECTION

Attribute selection, is a kind of dimensionality decrease, which can be related to substantial significance within category difficulties. Attribute Selection (FS) is the procedure of choosing the part associated with design attributes called 'attributes', taking out the unnecessary as well as unimportant factors for building robust learning models [31]. The selected attribute variables from the elements of the vector known as attribute vector Z_{SSE} . An easy as well as a fast process known as the Sequential Forward Selection

(SFS), a wrapper model, is recognized as an appropriate FS way around the security evaluation difficulty addressed herein. Of all the FS methods analyzed, the actual SFS technique was found to give better classification accuracy with a minimal number of selected attributes.

An attribute selection method has become utilized in order to lessen the efficient difficulty dimension along with a fresh considerably method of attaining high-speed regarding delivery and also great category precision to enhance the effectiveness and furthermore usefulness regarding large-scale power systems security evaluation is proposed.

Attribute selection is the process of selecting the actual component concerning distinctive capabilities, via getting rid of repeated as well as trivial elements. Chosen capabilities from the facets of the actual vector referred to as a feature vector symbolized as:

$$Z_{SSE} = (Z_1, Z_2, Z_3, \dots, Z_n)$$

One of the most prominent functions to be utilized regarding developing the security function tend to be chosen through a good repetitive process known as single ranking (SR) technically. The SR technique is the particular sequential manner in which 1 adjustable every time is going to be included into the current number of factors. The actual variable being included could be chosen as the 1 acquiring the best possible discerning power (quality value regarding F). The formula is regarding single ranking approaches to function as choice.

Step One: Determine the actual Fisher's rating (F) for that component (factors) for that design vector inside the coaching collection making use of Eq. (1).

An appropriate simple qualifying measure for selecting an adapter just like a function is going to be must supply additional data from the selection or perhaps group when compared with extra circumstances. The actual number related to valuing F known as Fisher's score shown in Eq. (1) offers a straightforward calculation involving the data content material in every adjustable as follow:

$$F(x_j) = \frac{|\mu_j^s - \mu_j^{is}|}{\sigma_j^s + \sigma_j^{is}} \quad (1)$$

where by μ_j^s (μ_j^{is}) would be the mean of the i^{th} feature in secure group (insecure class) style vector σ_j^s (σ_j^{is}) would be the standard deviation within the i^{th} feature with secure group (insecure class) style vector.

The Second Step: Start with a definite character vector Z_{SSE} = helps make the characteristic rely, $k = \text{one}$.

The Third Step: Pick the variable combined with the greatest F value as well as keep (blank) the original feature in the characteristic vector Z_{SSE} .

The Fourth Step: Establish the actual relationship coefficients between your selected characteristic, Z_k , as well as other factors in the design vector.

The Fifth Step: Get rid of all the elements that are very linked to Z_k (say with a correlation coefficient greater than 0.8). Consequently, customize the design vector.

The Sixth Step: Increase the actual character count number, i.e., $k = k + 1$.

The seventh Step: At this time, within the remaining elements to the design vector, select variable with greatest F value and also set aside inside characteristic vector Z_k .

Step eight: Duplicate via Step Four until the required volume of characteristics is becoming eliminated.

With regard to fixed security evaluation, the current degree of every bus and also the thermal power of all outlines should be within their boundaries. In SSE process, the particular placement within the power method is analyzed for several feasible contingencies by means of repairing non-linear excess weight motion equations couple of labelling or even groups. The device condition is, in fact, known as ‘Static Secure’ (SS-Binary one) whenever all the limitations mentioned in 3.1 are often satisfied for almost any provided backup. When somebody issues break ‘is identified performing a problem, the device situation is going to be known as ‘Static Insecure’ (SI-Binary zero).

Engineering common sense occasionally may decide on the actual enter attributes. However, this kind of choices is going to be very subjective using the chance of essential factors obtaining turned down. A typical approach to feature selection will be a consecutive feature choice, composed of two elements - a target function known as criterion and also a consecutive investigation formula. The real feature factors chosen through SFS technique can serve as an input data source regarding creating the actual classifier formula. The SFS technique utilized in the current function begins with an empty group of features and also encourages prospective client function subsets with the help of one attribute every time. For each prospective client perform component, SFS operates the actual 10-fold combine authorization through frequently contacting the actual qualifying criterion operate. The actual qualifying criterion operates is really a reduction calculate determining the amount of misclassification studies within the mix affirmation of every prospect feature part. This method has actually continued before the inclusion of many more characteristics produced absolutely no further reduction in the actual qualifying criterion operate.

In style recognition, characteristic choice can be a distinctive kind of dimensionality reduction. Attribute selection demands simplifying the amount of resources essential to clarify a substantial number of accurately]. Usually, the quantity of elements detailing the power plan situation in the style vector is big. Evaluation utilizing numerous elements generally requires a lot of storage area as well as computation power, leading to a lot more than suitable of coaching illustrations as well as poor generalization capacity concerning invisible examine illustrations. As a result, it could be necessary to determine relatively a couple of elements, referred to as capabilities that are unique for each of those two groups connected with styles. Feature selection is the method of selecting the actual component concerning distinctive capabilities, via removing repeated as well as trivial elements.

It ought to be mentioned that m has a smaller footprint compared to n, m and n becoming a volume of components in credit vector as well as a design vector, correspondingly.

5.0 PERFORMANCE EVALUATION

The correct classification rate (CCR) is a key gauge employed for analyzing one particular or even classifier. Nevertheless, CCR only can be inadequate regarding gauging a functionality of the classifier for a static security index dataset. Therefore, the true positive rate (TPR) or sensitivity, true negative rate (TNR) or specificity had been additionally utilized for this work to assess the actual overall performance regarding device studying techniques, as shown in Table 2.

Table 2 The procedures employed for assessing the efficiency of AI techniques

| Measure name | Formula |
|-----------------------------------|-----------------------------------|
| Correct classification rate (CCR) | $CCR = \frac{TP+TN}{TP+FP+FN+TN}$ |
| True positive rate (TPR) | $TPR = \frac{TP}{TP+FN}$ |
| True negative rate (TNR) | $TNR = \frac{TN}{TN+FP}$ |

where:

- TP (true positive): the number of correct classifications of the positive examples
- TN (true negative): the number of correct classifications of negative examples
- FP (false positive): the number of incorrect classifications of negative examples
- FN (false negative): the number of incorrect classifications of positive examples

After training and verification, the trained classifier was saved in the files and was utilized to improve the performance of the conventional static security evaluation policies.

6.0 RESULTS AND ANALYSIS

6.1 System Design and Presumptions

Power system utilized in simulations may be the IEEE 57- bus test system. This includes 7 generators models as well as 80 transmission lines. The utmost, minimal as well as foundation situation output within (MW) for every creation device are provided in table 3, where P_{min} will be the minimum output and also P_{max} will be the maximum output.

Table 3 Generation unit’s data

| | G1 | G2 | G3 | G6 | G8 | G9 | G12 |
|----------------------------|--------|-----|-----|-----|-----|-----|-----|
| P_{max}(MW) | 575.88 | 100 | 140 | 100 | 550 | 100 | 410 |
| P_{min}(MW) | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Base case(MW) | 128.9 | 0 | 40 | 0 | 450 | 0 | 310 |

Functional limitations tend to be selected randomly with regard to bus voltages 0.94 p.u. and 1.06 p.u. and for transmission lines congestion 100% of their rated apparent power. Additionally, (blank), the power flow is actually resolved with regard to N-1 transmission line contingency to check for the emergency limitations.

6.2 Impact of Attribute Selections on Training and Testing Dataset

In the data sets utilized for this research, it had been believed that the security position category belonged to the good category if a security position category had been safe. Alternatively, else, the security position belonged to the unfavourable category.

The outcomes of data creation and have a choice (selection) stages regarding fixed security evaluation are provided in Table 4.

Table 4 Data generation and features reduced for static security evaluation.

| Test case studies | 30 Bus | 300 Bus |
|--------------------------------|---------------|---------------|
| Operating scenarios | 176 | 203 |
| Static Positive(SP) cases | 96 | 119 |
| Static Negative(SN) cases | 80 | 84 |
| No. of pattern variables | 96 | 140 |
| No. of input features selected | 20 | 36 |
| Dimensionality reduction | 9.053% | 0.257% |

Bold values indicate the deducted value of dimensionality reduction, which is an important measure of feature selection.

7.0 RESEARCH WORKS COMPARISON

A comparison with other research works had been conducted to check the proposed RBFNN reliability.

Table 5 Performance measures of training and testing datasets

| | | 30 Bus | | 300 Bus | |
|--------|-----|-------------|--------------|----------|---------|
| | | Training | Testing | Training | Testing |
| RBF-NN | CCR | 97.5 | 98.00 | 96.4 | 97.00 |
| | TPR | 79.00 | 80.48 | 80.00 | 79.3 |
| | TNR | 94.68 | 97.7 | 95.00 | 96.5 |
| | CCR | 92.08 | 93.00 | 91.08 | 92.00 |
| NB | TPR | 89.79 | 88.96 | 89.7 | 88.55 |
| | TNR | 97.00 | 96.48 | 96.00 | 95.43 |
| | CCR | 93.54 | 94.12 | 92.50 | 93.4 |
| C4.5 | TPR | 91.40 | 89.43 | 91.40 | 88.8 |
| | TNR | 92.91 | 97.83 | 92.7 | 96.7 |
| | CCR | 85.85 | 88.90 | 85.3 | 87.90 |
| SVM | TPR | 84.00 | 83.53 | 84.00 | 82.55 |
| | TNR | 100.00 | 99.98 | 98.5 | 97.00 |
| ANFIS | CCR | 93 | 95.00 | 92.55 | 95.6 |
| | TPR | 83.93 | 74.83 | 83.5 | 73.5 |
| | TNR | 93.92 | 98.47 | 92.8 | 97.55 |

As shown in Tables 5, a comparison between RBFNN, SVM, NB, C4.5 and ANFIS classifier's for the systems data sets in both

the training and testing data sets in terms of three performance evaluation measures mentioned in section 6. Moreover, as illustrated in Table 5 the details of train and test data set classification results of 30 and 300 buses IEEE test. The classification results appear that the proposed classifiers provide a justly great correct classification rate (CCR). The RBFNN classifier is also capable of detecting unlabeled examples (test set) with significant accuracy. And as a result this makes RBFNN feasible for on-line security monitoring implementation.

The measures worst values underline font while, finest one are highlighted in bold font for both 30 and 300 bus IEEE test system. In the training phase, the optimum CCR values achieved by the proposed RBFNN and ANFIS of around 97.5%, 93% respectively, whereas, the averages of CCR for SVM, NB and C4.5 achieved are around 85.85%, 91.54% and 93.54% respectively.

In terms of CCR performance, as it can be seen from Tables 5, SVM, NB, C4.5 and ANFIS made competitive methods. However, for all data sets, it is apparent that the best TPR performance measure belongs to SVM, and the worst TPR belongs to RBFNN. The reason is that RBFNN tended to categorize the patterns, mostly as the majority class, which means the negative class and then led to the maximum value of TNR measure. Additionally, when dealing with imbalance data, SVM is a great choice because it was trained with a penalty (weight) options. A greater weight was indicating to a positive class, while fewer weights were indicating to a negative class. Therefore, and in the test phase, SVM could detect the positive or minority class (security status).

7.1 First Case Study, Pool Market

In the real collection sends (without any bilateral dealings), data concerning the prices for bids for that generator and also the provided for the clients are offered in Table 6.

Table 6 Stacks of bids and offers

| | GenCo. | P (MW) | y (\$/MWh) |
|----------|----------|------------|-------------|
| B | 6 | 100 | 18.5 |
| I | 2 | 100 | 23 |
| D | 1 | 50 | 26.5 |
| S | 1 | 200 | 17 |
| | 8 | 50 | 21.5 |
| | 6 | 100 | 25 |
| | 9, 12 | 100, 100 | 19 |
| | 3 | 50 | 25.5 |
| | DisCo. | P (MW) | y (\$/MWh) |
| | 1 | 100 | 18 |
| O | 1 | 100 | 21 |
| F | 2 | 200 | 25 |
| F | 2 | 200 | 25 |
| E | 6 | 100 | 26.5 |
| R | 6 | 50 | 19 |
| S | 2 | 50 | 20 |
| | 9 | 100 | 22 |

where P will be the provided power within MW, and you will be the cost of the corresponding block in\$/MWh.

To the provided data, the actual need and also production shapes tend to be matched up to determine the system marginal price (SMP) and as well the amount regarding power within the collection market. Figure 4 demonstrates the actual complementing in between generator prices for bids and besides needs provides.




Figure 4 Matching of generator bids and demand offers

Through the junction associated with these types of two shapes, we all determine which in this situation, an SMP is going to be arranged from 20.00 \$/MWh, and the 500 MWh is going to be exchanged by this particular collection market place.

It ought to be mentioned when the actual price-demand curve intersects the actual side to side required as well as recognized. Nevertheless, all the originally recognized prices for bids on the minor generators tend to be proportionally shaved to ensure that generation as well as the need tends to be well balanced. Likewise, if the price-demand curve intersects the actual up and down the area of the price-production curve (as in Figure 4), and then a discussing could be around the need aspect. Which is, just about all generators may create as much as their own final recognized MW, however, at first recognized minor need prices for bids could be proportionally shaved?

The steady-state security evaluation voltage profile is illustrated in Figure 5.







Figure 5 Pool voltage profile and lines

In Figure 5, many lines are within the boundary other than collection number one is very large packed (290 MW). The error during the training process in Figure 6 was acceptable and extremely low, where it started with a greatly high value and during the training process reached an average value of 0.0038

and 0.0048 for 30 and 57 IEEE test systems respectively within 2 and 9 epochs. The computational time was 0.0795 and 0.08 seconds; this is the ability of NN to have a very fast learning algorithm.



30 Bus training performance



57 Bus training performance

Figure 6 The pool market training performance

7.2 Second Research Study, Bilateral Contract

As shown in Table 7, two bilateral agreements revealed among GenCo.2 and Genco.3 along with DisCo.7 inside levels of 50 MW each and every are thought to enhance the actual transmission line congestion within the collection market place.

Table 7 Bilateral transactions

| Transaction | GenCo. | DisCo. | MW/h |
|-------------|--------|--------|------|
| T1 | 2 | 7 | 50 |
| T2 | 3 | 7 | 50 |







Figure 7 Bilateral voltage profile and line flow

Subsequent Figure 7 displays the actual current user profile and also the transmission lines within the bilateral Agreements. It may be observed obviously that voltages tend to be inside the boundary, and all line's thermal power are below optimum line power.

The error during the training process in Figure 8 was acceptable and extremely low, where it started with a greatly high value and during the training process reached an average value of 0.5 and 1 for 30 and 57 IEEE test systems respectively within 15 and 20 epochs. The computational time was 0.09 and 0.1 seconds; this is the ability of NN to have a very fast learning algorithm.



30 Bus training performance



57 Bus training performance

Figure 8 The bilateral contract training performance

8.0 CONCLUSION

Artificial intelligence techniques guarantee option and also an effective approach to evaluation for that big power system than the traditional technique. RBF-NN for classification and performance evaluation of static security assessment in deregulated power system is proposed. All of these techniques may effectively be relevant to assess fixed security evaluation associated with power methods within the real-time. Data generation and also the impact attribute selection upon training and also testing is highlighted. Furthermore, in the three situations research several summaries could be deduced, which is within the collection program you will find had been a few collections had been large packed including collection 1(290 MW), but as we put into action the two bilateral agreements with the actual thermal power within line 1 decreased in order for 225 MW. So that in this study, bilateral contracts come to improve the static security constrains. To assess the actual overall performance regarding studying techniques, this research proposes performance evaluation schemes used vis CCR, TPR and TNR. The simulation results have shown the powerfulness of the proposed RBFNN method as compare to other techniques. The classification results have shown that the proposed classifiers give a fairly high correct classification rate (CCR). By simply considering the computational serious amounts of precision from the systems, it may be safely figured that RBF-NN is actually suitable classifier with regard to quick online static security evaluation associated.

Acknowledgement

The authors would like to thank Universiti Teknolgi Malaysia (UTM) for providing facilities and the reviewers for their constructive and helpful comments.

References

- [1] Shahidehpour, M., F. Tinney, and Y. Fu. 2005. Impact of Security nn Power Systems Operation. Proceedings of the IEEE, 2005. 93(11): 2013–2025.
- [2] Lai, L. L. 2001. *Power System Restructuring and Deregulation: Trading, Performance and Information Technology*. Wiley.
- [3] Weber, C. 2005. *Uncertainty in the Electric Power Industry: Methods and Models for Decision Support*. Vol. 77. Springer Verlag.
- [4] Fang, R. and A. David. 1999. Optimal Dispatch Under Transmission Contracts. *Power Systems, IEEE Transactions*. 14(2): 732–737.
- [5] Galiana, F. D., I. Kockar, and P. C. Franco. 2002. Combined Pool/bilateral Dispatch. I. Performance of Trading Strategies. *Power Systems, IEEE Transactions*. 17(1): 92–99.
- [6] Cheng, J., D. McGillis, and F. Galiana. 1998. Bilateral Transactions Considered as Interconnections in a Deregulated Environment. IEEE.
- [7] Hamoud, G. 2000. Feasibility assessment of Simultaneous Bilateral Transactions in a Deregulated Environment. *Power Systems, IEEE Transactions*. 15(1): 22–26.
- [8] Ozdemir, A., J. Y. Lim, and C. Singh. 2002. Line Outage Simulation by Bounded Network Solution. IEEE.
- [9] Pang, C. and A. Wood. 1975. Multi-area Generation System Reliability Calculations. *Power Apparatus and Systems, IEEE Transactions*. 94(2): 508–517.
- [10] Billinton, R. 1969. Composite System Reliability Evaluation. *Power Apparatus and Systems, IEEE Transactions*. 4: 276–281.
- [11] Ranade, S. J. and R. Sullivan. 1981. A Reliability Analysis Technique for Bulk System Planning. *Power Apparatus and Systems, IEEE Transactions*. 7: 3658–3665.
- [12] Mikolinnas, T., W. Puntel, and R. Ringlee. 1982. Application of Adequacy Assessment Techniques for Bulk Power Systems. *Power Apparatus and Systems, IEEE Transactions*. 5: 1219–1228.
- [13] Mamandur, K. and G. Berg. 1982. Efficient Simulation of Line and Transformer Outages in Power Systems. *Power Apparatus and Systems, IEEE Transactions*. 10: 3733–3741.
- [14] Kirschen, D. S. 2002. Power System Security. *Power Engineering Journal*. 16(5): 241–248.
- [15] Pang, C. K., A. J. Koivo, and A. H. El-Abiad. 1973. Application of Pattern Recognition to Steady-state Security Evaluation in a Power System. *IEEE Transactions on Systems, Man and Cybernetics, SMC-3(6)*: 622–631.
- [16] Pang, C. K., et al. 1974. Security Evaluation in Power Systems Using Pattern Recognition. *IEEE Trans Power Appar Syst, PAS-93(3)*: 969–976.
- [17] Hassan, L.H., et al. 2013. Current State of Neural Networks Applications in Power System Monitoring and Control. *International Journal of Electrical Power & Energy Systems*. 51: 134–144.
- [18] Seyed Javan, D., H. Rajabi Mashhadi, and M. Rouhani. 2013. A Fast Static Security Assessment Method Based on Radial Basis Function Neural Networks Using Enhanced Clustering. *International Journal of Electrical Power & Energy Systems*. 44(1): 988–996.
- [19] Kalyani, S. and K. S. Swarup. 2012. Design of Pattern Recognition System for Static Security Assessment and Classification. *Pattern Analysis and Applications*. 15(3): 299–311.
- [20] Khattab, H., et al. 2012. Gene Expression Programming for Static Security Assessment of Power Systems. *Power and Energy Society General Meeting, IEEE, IEEE*.
- [21] Hashemi, S. and M. R. Aghamohammadi. 2013. Wavelet based Feature Extraction of Voltage Profile for Online Voltage Stability Assessment Using RBF Neural Network. *International Journal of Electrical Power & Energy Systems*. 49: 86–94.
- [22] Wu, D. H., Y. Fu, and J. S. Wang. 2013. Assessment of Information System Assurance Capability Based on SVM. *Applied Mechanics and Materials*. 241: 275–279.
- [23] Chen, X. and Y. Li. 2012. Network Security Evaluation Based on Support Vector Machine. Proceedings of the 2nd International Conference on Green Communications and Networks (GCN 2012). Volume 3, 2013: Springer.
- [24] Ye, S., et al. 2012. Power System Transient Stability Assessment Based on Adaboost and Support Vector Machines. *Power and Energy Engineering Conference (APPEEC), 2012 Asia-Pacific, IEEE*.
- [25] Swarup, K. S. 2008. Artificial Neural Network Using Pattern Recognition for Security Assessment and Analysis. *Neurocomputing*. 71(4): 983–998.
- [26] Zhou, Q., J. Davidson, and A. Fouad. 1994. Application of Artificial Neural Networks in Power System Security and Vulnerability Assessment. *Power Systems, IEEE Transactions*. 9(1): 525–532.
- [27] Wehenkel, L. A. 1997. *Automatic Learning Techniques in Power Systems*. Springer.
- [28] Niebur, D. and A. J. Germond, 1992. Power System Static Security Assessment Using the Kohonen Neural Network Classifier. *Power Systems, IEEE Transactions*. 7(2): 865–872.
- [29] Mohammadi, M. and G. Gharehpetian. 2008. Power System On-line Static Security Assessment by Using Multi-class Support Vector Machines. *Journal of Applied Sciences*. 8(12): 2226–2233.
- [30] Momoh, J. A., Y. Xia, and G. D. Boswell. 2008. Locational Marginal Pricing for Real and Reactive Power. IEEE.
- [31] Liu, H. and L. Yu, 2005. Toward Integrating Feature Selection Algorithms for Classification and Clustering. *Knowledge and Data Engineering, IEEE Transactions*. 17(4): 491–502.